



Kingston Water Supply Management Protocol – A SWMI Grant Project

**NEWWA Spring Conference
April 2, 2014**


**Kristen Berger, P.E., ENV SP
Comprehensive Environmental Inc.**





Presentation Outline

- Objective
- System Overview
- Specific Goals and Challenges
- Historical Data
- Hydraulic Model and Scenario Simulations
- Findings and Summary





Objectives

- Purpose - Demonstrate how Massachusetts communities can shift withdrawals between their wells for benefit of drinking water supply and environment (optimization and/or minimization depending on specifics)
- Balance water quality, cost to customers and compliance with WMA permits and pending SWMI regulations



System Overview

- Two pressure zones: High and Low
- 3 water storage tanks: 2 in Low, 1 in High
- 10-yr Average Day Demand: 1.19 – 1.47 mgd
- 10-yr Max Day Demand: 2.38 – 3.05 mgd
- Summer Average Day Demands
 - Low Zone \approx 1.3 mgd
 - High Zone \approx 0.4 mgd
- Sources in Unassessed GWL Basin – South Coastal Basin
- Sources both Registered and Permitted
 - Low Zone: 5 Wells Registered – 0.99 mgd Authorized
 - Low Zone: 1 Well Permitted – 0.81 mgd Authorized
 - High Zone: 1 Well Permitted – 1.44 mgd Authorized




Figure 1-2
 Sustainable Water Management Initiative (SWMI)
 Grant Program
Water System Map
 Kingston, Massachusetts
 June 2013

LEGEND

Public Water Supply	Water Distribution Pipes	Hydrography
Ground Water Supply	Diameter	Reservoir
Surface Water Supply	2"	Wetland, Marsh, Swamp or Bog
Water Supply Features	4"	Cranberry Bog
Lime Feed Facility	6"	Salt Wetlands
Pump Station	8"	Straw, Lake or Pond
PPV	10"	State Hdr. Head
Reservoir Station	12"	Bay, Ocean
Pump Station	14"	Stream, Brook
Tank	16"	Collocated History Resource
Stream Gaging Station	Pressure Zone	Town Boundary
	Major Basin Boundary	
	Subbasin Boundary	

North arrow and scale bars:

- Scale: 0 to 7,500 Feet
- Scale: 0 to 1.5 Miles

Comprehensive Environmental Incorporated



Specific Goals

- Optimize use of Trackle Pond Well located in High Zone
- Minimize use of Registered wells located in Low Zone, proximate to Jones River
- No direct correlation has been made between Kingston water source pumpage and Jones River streamflow, but Town is a Green Community and supports efforts to minimize perceived environmental impacts



Supply Challenges

- WMA Constraints – Withdrawal Balancing
 - Total withdrawal from Registered wells
 - Individual withdrawals from Permitted wells
- Varying Water Quality of Sources
- System Hydraulics (existing PRV uncontrolled flows, vault, not communications)
- Future blending of Chlorinated water with water from untreated sources
- Concerns over Potential Environmental Impacts to Jones River streamflow



Water Quality – Manganese Issues

- SMCL for manganese is 0.05 mg/L
- Trackle Pond Well Mn \approx 0.15 mg/L
 - Recent years reduced pumping rate from 1,000 gpm to 300 gpm to mitigate Mn & complaints
 - Pumping more would introduce more Mn into the distribution system
 - Currently constructing Manganese Removal Treatment Facility
 - Residual chlorine leaving facility will be \approx 0.2 mg/L




Historical Pumping Data






Representative Dry Year - 2005






2005 Streamflow Data Jones River USGS 01105870





Hydraulic Model


- Programmed model to simulate extended day runs with hourly demand changing throughout the day based on peak week






Simulations

- Current Operation as Separate Zones
 - Scenario 1 – South St Lead
 - Scenario 2 – Grassy Hole Lead
- PRV Transfer from High to Low (similar to existing ability)
 - Scenario 3 – South St Lead
 - Scenario 4 – Grassy Hole Lead
- FCV Transfer from High to Low
 - Scenario 5 – South St Lead
 - Scenario 6 – Grassy Hole Lead
- FCV Transfer from High to Low
 - Scenario 7 – FCV Lead, South St 2nd
 - Scenario 8 – FCV Lead, Grassy Hole 2nd






Scenario 1 - Current Operation as Separate Zones – South St Lead





Scenario 1 – Water Age




Time Browser

Time: 0.00

Time from Start (hours) | Time (hours)

0.000	0.00
12.000	12.00
24.000	24.00
36.000	36.00
48.000	48.00
60.000	60.00
72.000	72.00
84.000	84.00
96.000	96.00
108.000	108.00
120.000	120.00
132.000	132.00
144.000	144.00





Approximate Location of Transfer from High Zone to Low Zone

Figure 1-2
Sustainable Water Management Initiative (SWMI)
Grant Program
Water System Map
Kingston, Massachusetts
June 2013

LEGEND

Public Water Supply	Water Distribution Pipes	Hydrography
Ground Water Supply	Diameter	Reservoir
Surface Water Supply	2"	Wetland, Marsh, Swamp or Bog
Water Supply Features	4"	Cranberry Bog
Lime Feed Facility	6"	Salt Wetlands
Pump Station	8"	Straw, Lake or Pond
PPV	10"	Tidal Flat, Shrub
Booster Station	12"	Bay, Ocean
Pump Station	14"	Stream, Brook
Tank	16"	Collocated History Resource
Stream Capping Station	Pressure Zone	Town Boundary
	Major Basin Boundary	
	Subbasin Boundary	

Comprehensive Environmental Incorporated

Scale: 0 to 7,500 Feet / 0 to 1.5 Miles



Scenarios with PRV

- Uses Pressure Reducing Valve (PRV) transfer from High to Low
- PRV delivers inconsistent flow from High Zone to Low Zone – Similar to how existing PRVs operate
- When Lag Pump Station are activated, PRV flow decreases - PRV maintains system pressure not flow rate
- Hydraulics in Low Zone indicate preference for well supply pumps over PRV
- Goal is to rely more on Permitted well in High Zone and less on Registered wells in Low Zone




Scenarios with FCV

- Flow Control Valve (FCV) allows for more consistent flow to Low Zone, able to set at consistent rate of 600 gpm
- Evaluated Low Zone supply pumps as lead versus FCV as lead supply in Low Zone
- Programmed model to simulate the progression of chlorine residual from future Trackle Pond Manganese Removal Treatment Facility through the Low Zone
- Some Low Zone wells have manganese (up to 0.15 mg/L) that would adversely react with the residual chlorine




Scenario 7 – Proposed FCV Transfer from High to Low – FCV Lead, South St 2nd






Scenario 7 – Water Age





Scenario 7 - Chlorine





Findings

- FCV – No negative impacts on hydraulics
- Residual chlorine progress analysis indicates could have water quality issues in Low Zone
- With FCV as lead supply, residual chlorine could flow to majority of Low Zone
- May need de-chlorination at transfer location



System Modifications

- Work required at existing Booster Pump Station for permanent transfers from High Zone to Low Zone:
 - Removal of one of three booster pumps;
 - Installation of flow control valve and appurtenances and programming;
 - Installation of residual chlorine analyzer;
 - Installation of a de-chlorination system using sodium bisulfite (if needed).



Low Zone Supply Management Protocol

Month	Week 1	Week 2	Week 3	Week 4
April	South St	1-86	South St	1-86
	Millgate	Soules Pond	Millgate	Soules Pond
	Soules Pond	Millgate	Soules Pond	Millgate
	Grassy Hole	South St	Grassy Hole	South St
May	HZ Transfer	HZ Transfer	HZ Transfer	HZ Transfer
	1-86	South St	Grassy Hole	1-86
	Soules Pond	Millgate	Soules Pond	Soules Pond
	Millgate	Soules Pond	Millgate	Millgate
June	HZ Transfer	HZ Transfer	HZ Transfer	HZ Transfer
	South St	Grassy Hole	1-86	South St
	Millgate	Soules Pond	Soules Pond	Millgate
	Soules Pond	Millgate	Millgate	Soules Pond
July	HZ Transfer	HZ Transfer	HZ Transfer	HZ Transfer
	Grassy Hole	1-86	South St	Grassy Hole
	Soules Pond	Soules Pond	Millgate	Soules Pond
	Millgate	Millgate	Soules Pond	Millgate
August	HZ Transfer	HZ Transfer	HZ Transfer	HZ Transfer
	1-86	South St	Grassy Hole	1-86
	Soules Pond	Millgate	Soules Pond	Soules Pond
	Millgate	Soules Pond	Millgate	Millgate



Summary

- No direct correlation has been made between pumpage of Town's wells and Jones River streamflow
- Town is willing to optimize authorized (registered and permitted) pumpage to reduce reliance on the wells closest to Jones River in summer
- Implementing High to Low Zone transfers after Trackle Pond Manganese Removal Treatment Facility on-line: FCV installation being funded by 2014 SWMI Grant (with provisions for dechlorination)
- Trackle Pond Well will not be able to supply entire demand - wells in Low Zone will still need to operate during summer and low streamflow periods (peak hour demands reach 2,000 gpm), but at reduced flow rates



Acknowledgements

Town of Kingston Board of Water Commissioners

Matthew Darsch, Superintendent

Michael Ohl, P.E., CEI

Jessica Cajigas, CEI

SWMI Grant Program Administrators

Questions?

Kristen Berger, P.E., ENV SP

Comprehensive Environmental Inc.

kberger@ceiengineers.com

508.281.5160